1. Action Requested/Purpose:

Approve construction of a water distribution and gravity collection system serving *Haitian Road Extension* to provide potable water service, fire protection and sanitary sewer service to this proposed industrial development. This is a Developer Contributed asset project located along the north side of Alico Road approximately 2 miles west of I-75.

2. What Action Accomplishes:

Provides adequate utility infrastructure to support development of the subject property and complies with the Lee County Utilities Operations Manual.

3. Management Recommendation:

Approval.

* -L. L					
4. Departmental Category	: 10	CIOA		5. Meeting Date	0-2005
6. Agenda: 7		uirement/Purpo	se (specify)	8. Request Initiated	
X Consent		Statute		Commissioner	/ \ \ \ \
Administrative		Ordinance		Department	Rublic Works
Appeals		Admin. Code		Division	, Utilities
Public	X	Other	Approval	By:	9/1/05
Walk-On		_		Rick Diaz	P./E., Utilities Director
9. Background:					
The Letter of Intent has been				•	

The review fee has been paid.

The plans have been reviewed for conformance to the Lee County Utilities Operations Manual.

The project is to construct 7,747'± of 12" diameter water main; 16 fire hydrants; 6,274' ± of 10" diameter gravity main; 16 manholes; 1,200'± of 6" diameter force main; 1,475'± of 4" diameter force main and two lift stations. These main extensions are being permitted as dry lines; therefore, no connection fees are due at this time.

Project Location Map---copy attached.

No funds required.

SECTIONS 04 & 05 TO

TOWNSHIP 46S

RANGE 25E

DISTRICT # 5 COMMISSIONER ALBION

10. Review for Scheduling: Purchasing Department Human County County Manager / Other or **Budget Services** P.W. Director Director Resources Attorney Contracts A harmon Analyst Risk Grants Mgr. N/A N/A Chrondel **J. L**avender S. Coovert J. Lavender T. Osterhout Date: Date: 11. Commission Action: RECVU. RECEIVED BY Approved COUNTY ADMIN **Deferred** Denied Other COUNTY ADMIN FORMARDED TO: forwarded to: 1

