



Procurement Management Department
 1500 Monroe Street 4th Floor
 Fort Myers, FL 33901
 Main Line: (239) 533-8881
 Fax Line: (239) 485-8383
www.leegov.com/procurement

Posted Date: July 24, 2019

Solicitation No.: B190367BAG

Solicitation Name: Alva Boat Ramp Renovation

Subject: Addendum Number 5

The following represents clarification, additions, deletions, and/or modifications to the above referenced bid. This addendum shall hereafter be regarded as part of the solicitation. Items not referenced herein remain unchanged, including the response date. Words, phrases or sentences with a strikethrough represent deletions to the original solicitation. Underlined words and bolded, phrases or sentences represent additions to the original solicitation.

1) SEE ATTACHED – ADDENDUM 5 BID SCHEDULE

2) QUESTIONS/ANSWERS

1.	In regard to the soil probs, can we have in writing a description of the probing technique used and blow counts used to reach refusal.
Answer	Sediment probes were conducted by a diver using a 12' long x 3/4" diameter steel jet probe. Water was supplied to the probe by a gas powered centrifugal pump. An RTK GPS was used to record the position and elevation of each probe. If the entire length of pipe penetrated the channel bottom sediment, the probe location was identified as No Refusal. At locations where the pipe could not fully penetrate the sediment, the probe tip elevation was recorded. No power equipment other than the pump or hammers were used. The diver stood on the bottom and manually manipulated the probe.
2.	Given the complexity of this project, and the reasonable construction concerns. Can an estimated budget be released, for the purpose of the contractor's to understand the engineers assumed baseline to complete this project.
Answer	As previously stated in Addendum 1, see Article 13.3 of the solicitation Terms and Conditions.
3.	Several of our site subcontractors that their take offs for the shell parking are SIGNIFICANTLY lower that what is listed on the proposal form.
	Should we bid by our take offs or bid "apples to apples" and match the proposal quantities?

Answer	The quantity for Bid Item 7G - Shell Parking listed in the Schedule of Values is 510 CY. We have reviewed the construction plans and cross section detailing how/where this material is to be placed and determined that the quantity should be 150 CY. Please see revised Bid Proposal, available in our download documents section.
---------------	--

ALL OTHER TERMS AND CONDITIONS OF THE SOLICITATION DOCUMENTS ARE AND SHALL REMAIN THE SAME.



Adam Brooke
Lee County Procurement Management