

Posted Date: July 31, 2020

Solicitation No.: B200316BJB

Solicitation Name: Principia Drive Water Main Replacement

Subject: Addendum Number 4

The following represents clarification, additions, deletions, and/or modifications to the above referenced bid. This addendum shall hereafter be regarded as part of the solicitation. Items not referenced herein remain unchanged, including the response date. Words, phrases or sentences with a strikethrough represent deletions to the original solicitation. Underlined words and bolded, phrases or sentences represent additions to the original solicitation.

1. QUESTIONS/ANSWERS

1.	The HDPE, as shown on original and addendum, the plan profile says HDPE, but if you go to the cut sections, it shows deflections as DIP? Is this how the it supposed to be for the HDPE, with no ductile on the deflections? All drawings show the same?
Answer	Ductile iron pipe, DIP, is acceptable for all deflections. This includes deflections for HDPE as shown on the profiles. Note DIP deflections are also acceptable for both bid alternates "A-1" and "B-1".
2.	If we go the Alternate A all as HDPE directional, what do we do with the bid item 11. Furnish & Install Vertical and Horizontal Deflections, this is assuming as directional drill the Deflections we no longer be needed?
Answer	Bid Item 11 is for any deflections that are needed as depicted on the plans. DIP is acceptable for all deflections for both HDPE water mains and DIP water mains.
3.	Alternate B, so this shows the DIP as shown on the drawings, what about the deflections, do we just put the fittings there?
Answer	All labor and materials including fittings, valves, etc. as shown on the plans is to be included in the bid price. The Contractor is to provide a complete and fully functional water main system.
4.	Can we do Alternate B and open cut the HDPE, it says Directional?
Answer	For HDPE open cut, bid Alternate "A".

2. **INQUIRIES / CLARIFICATIONS:** The cut-off time has occurred for inquiries submitted by potential bidders. The County will no longer accept questions for this solicitation.

BIDDER/PROPOSER IS ADVISED, YOU ARE REQUIRED TO ACKNOWLEDGE RECEIPT OF THIS ADDENDUM WHEN SUBMITTING A BID/PROPOSAL. FAILURE TO COMPLY WITH THIS REQUIREMENT MAY RESULT IN THE BIDDER/PROPOSER BEING CONSIDERED NON-RESPONSIVE.

ALL OTHER TERMS AND CONDITIONS OF THE SOLICITATION DOCUMENTS ARE AND SHALL REMAIN THE SAME.

Procurement Analyst
Procurement Analyst Direct Line: 239-533-8887
Lee County Procurement Management