



Procurement Management Department
 2115 Second Street, 1st Floor
 Fort Myers, FL 33901
 Main Line: (239) 533-8881
 Fax Line: (239) 485-8383
www.leegov.com/procurement

Posted Date: March 21, 2023

Solicitation No.: B230074CJV

Solicitation Name: Fort Myers Beach Temporary Switchgear & Electrical Equipment

Subject: Addendum Number 3

The following represents clarification, additions, deletions, and/or modifications to the above referenced bid. This addendum shall hereafter be regarded as part of the solicitation. Items not referenced herein remain unchanged, including the response date. Words, phrases or sentences with a strikethrough represent deletions to the original solicitation. Underlined words and bolded, phrases or sentences represent additions to the original solicitation.

1. ATTACHMENT: NONE

2. QUESTIONS/ANSWERS

1.	Where is the existing FPL transformer we need to connect the switchgear to?
Answer	See attachment E-199, included in the original solicitation package.
2.	Are the bold MCC6 & MCC7 feeders on the one line picked up under another project?
Answer	All feeders out of the main switchgear must be fed from temporary cable.
3.	What are the projected start & completion dates if any?
Answer	Commencement date would be determined based on approval by the Lee County Board of County Commissioners. The temporary switchgear may be installed up to five (5) years.
4.	Will each MCC (#6 and #7) require only a single cable run (good for 1200 amps) from the temporary switchgear?
Answer	This should be based on the full load for each 1200 amp main.
5.	We don't need to provide all the breakers found in each MCC, correct?
Answer	Breakers in the temporary switchgear should match the one-line drawings, E-200 of the original solicitation package.

BIDDER/PROPOSER IS ADVISED, YOU ARE REQUIRED TO ACKNOWLEDGE RECEIPT OF THIS ADDENDUM WHEN SUBMITTING A BID/PROPOSAL. FAILURE TO COMPLY WITH THIS REQUIREMENT MAY RESULT IN THE BIDDER/PROPOSER BEING CONSIDERED NON-RESPONSIVE.

ALL OTHER TERMS AND CONDITIONS OF THE SOLICITATION DOCUMENTS ARE AND SHALL REMAIN THE SAME.

Christy VanAllen

Procurement Analyst: Christy VanAllen
 Direct Line: 239-533-8839
 Lee County Procurement Management