



Procurement Management Department
2115 Second Street, 1st Floor
Fort Myers, FL 33901
Main Line: (239) 533-8881
Fax Line: (239) 485-8383
www.leegov.com/procurement

Posted Date: February 13, 2023

Solicitation No.: B230094LND

Solicitation Name: Lift Station Control Panel Replacement - FEMA

Subject: Addendum Number 2

The following represents clarification, additions, deletions, and/or modifications to the above referenced bid. This addendum shall hereafter be regarded as part of the solicitation. Items not referenced herein remain unchanged, including the response date. Words, phrases or sentences with a strikethrough represent deletions to the original solicitation. Underlined words and bolded, phrases or sentences represent additions to the original solicitation.

1. OPEN DATE / BIDS DUE EXTENSION

FROM: FEBRUARY 17, 2023 at 2:30 PM

TO: FEBRUARY 23, 2023 at 2:30 PM

2. REPLACE:

a. Bid Schedule in its entirety

The Bid Schedule has been updated and a revised Bid Proposal Form has been uploaded to the project webpage on the Lee County Procurement website.

Bidder/Contractor MUST use the Revised Bid Proposal form when submitting their bid. Failure to do so will result in Bidder/Contractor being deemed non-responsive and therefore ineligible for award.

3. ATTACHMENT:

a. REVISED 2-13-2023 – Bid Schedule

4. QUESTIONS/ANSWERS

1.	Please confirm the basis of award. It appears there is a conflict within 26.3. Is the County intending to award to the lowest responsive & responsible bidder, or will there be an attempt to “cherry pick” line items between multiple bidders?
Answer	As mentioned in the solicitation documents on page 15 under Special Conditions item 2 Basis of Award number 2.1 states “<i>The basis of award shall be determined by the <u>lowest Project Total Bid</u> of the most responsive, responsible, and qualified Vendor meeting all bid specifications</i>”.
2.	No bill of material for the control panels appears to be available through the links provided. Are these available?
Answer	As mentioned in the solicitation documents on page 26 under Scope of Work and Specifications section 4 Shop Drawings, the list (also referred by County staff as Bill) of material shall be provided by the manufacturer following County Specs and standards. The list shall include all of the components used in the manufacture of the panels.

3.	Line Item B1 on the supplied bid form indicates 122 EA; there appear to be differences in quantities/sizes for this line item based on the different horsepower for each control panel. Please clarify.
Answer	The Bid Form has been revised to include the Junction Box that goes with the corresponding Control Panel as a single line item. Vendor shall bid each control panel and junction box as one Unit. All Junction Boxes are Duplex. Other specifications can be found in the technical specifications found in the solicitation document on page 27 under Scope of Work and Specifications section 7 Technical Specification, item 7.1.3 Lift Station Electrical Standards.
4.	We are unable to locate any information on acceptable component manufacturers. For example the controller "CT1" is not identified on any provided documentation. Please provide a list of acceptable manufacturers.
Answer	The following are the County standard manufacturers: - Selector Switches, Indicator Lights, Breakers, Motor Starters, and VFDs are Schneider products. - Phase Monitors are made by Diversified or Macromatic. - Generator Plug must be a Pyle National Quelarc 100-amp J series receptacle. - PLC must be Schneider Scada Pack 474 to communicate with our Scada system. - HMI must be C-More EA9-T7CL. All other products must meet the UL-508 and NEC codes and standards.
5.	Is there a provision for billing stored materials?
Answer	Payment for any stored materials will be discussed between awarded vendor and department. After discussion, there is a stored materials form that shall be completed by the vendor. Additional information shall also be submitted including, but not limited to, pictures of the materials, invoices, and a site inspection by Lee County Utilities personnel, if local.
6.	No bonding information is included; please confirm that a bid bond or a performance bond will not be required.
Answer	This project <u>Does Not</u> require a Bid Bond or a Payment/Performance Bond to be submitted.
7.	Will the County consider extending the bid submittal due date?
Answer	It has been decided to push the opening of this bid to Thursday, February 23, 2023, at 2:30pm.

BIDDER/PROPOSER IS ADVISED, YOU ARE REQUIRED TO ACKNOWLEDGE RECEIPT OF THIS ADDENDUM WHEN SUBMITTING A BID/PROPOSAL. FAILURE TO COMPLY WITH THIS REQUIREMENT MAY RESULT IN THE BIDDER/PROPOSER BEING CONSIDERED NON-RESPONSIVE.

ALL OTHER TERMS AND CONDITIONS OF THE SOLICITATION DOCUMENTS ARE AND SHALL REMAIN THE SAME.



Lilla Davis
Procurement Analyst Direct Line: 239-533-8857
Lee County Procurement Management