



Procurement Management Department  
2115 Second Street, 1<sup>st</sup> Floor  
Fort Myers, FL 33901  
Main Line: (239) 533-8881  
Fax Line: (239) 485-8383  
[www.leegov.com/procurement](http://www.leegov.com/procurement)

**Posted Date:** February 15, 2023

**Solicitation No.:** B230095LND

**Solicitation Name:** Lift Station Generator Replacement - Materials Package - FEMA

**Subject:** Addendum Number 2

The following represents clarification, additions, deletions, and/or modifications to the above referenced bid. This addendum shall hereafter be regarded as part of the solicitation. Items not referenced herein remain unchanged, including the response date. Words, phrases or sentences with a strikethrough represent deletions to the original solicitation. Underlined words and bolded, phrases or sentences represent additions to the original solicitation.

**1. ATTACHMENT: NONE**

**2. QUESTIONS/ANSWERS**

1.	1.01.A Is this an equipment and installation bid or just equipment only?
Answer	<b>This bid is for equipment/material only. This can be found in the solicitation documents on page 28 under Scope of Work and Specifications, section 7 Technical Specifications, item 7.3 “Installation is not included and shall be completed by County Staff.”</b>
2.	1.01.F Are all the equipment to be 277/480 volts, 3 phase?
Answer	<b>As stated in the solicitation documents Revised Attachment A, under Part 1 General, number 1.01 SCOPE OF WORK, item F “The generator Unit shall be as manufactured by Cummins-Onan, or equal, with a standby rating of ___kW, ___kVA, 1800RPM, 0.8 power factor, 277/480Volt, 3 phase, 60 Hertz, 4 wire including radiator fan and all parasitic loads.” Please bid as specified.</b>
3.	2.07.D.6 The generator will come with the battery charger mounted within the enclosure, will this be acceptable in lieu of the transfer switch?
Answer	<b>As stated in the solicitation documents Revised Attachment A, under Part 2 Products, number 2.07 AUTOMATIC STARTING SYSTEM, item D 6, “Locate Charger in the automatic transfer switch.” Please bid as specified.</b>
4.	2.08.C Is there an HP motor size for each site? How many and will they be starting sequentially? Will the motors have soft starter or it will be across the line starting method?
Answer	<b>Please bid as specified. The HP motor size, quantity, and starting sequence is beyond the scope of this material-only bid</b>

5.	Are there any engineering Riser Diagrams available?
Answer	<b>This solicitation is for materials only, the engineering riser diagrams are not necessary. There are electrical standards plans available on the Lee County Utilities website, however they are not engineering drawings. To view the available electrical standards, please go to the Lee County Utilities website found at <a href="https://www.leegov.com/utilities/design-manual/proposed-lift-station-electrical-standards">https://www.leegov.com/utilities/design-manual/proposed-lift-station-electrical-standards</a></b>
6.	If an installation is required, will site visits be available?
Answer	<b>As stated in the solicitation documents on page 28 under Scope of Work and Specifications, section 7 Technical Specifications, item 7.3 “<i>Installation is not included and shall be completed by County Staff.</i>” This bid is for equipment/material only. No site visits are necessary.</b>
7.	Will there be an extension to the existing bid date due to questions & answers?
Answer	<b>At this time, no extension to the bid opening date is granted. The current opening date is Monday, February 20, 2023, at 2:30pm as stated within the solicitation documents.</b>

**BIDDER/PROPOSER IS ADVISED, YOU ARE REQUIRED TO ACKNOWLEDGE RECEIPT OF THIS ADDENDUM WHEN SUBMITTING A BID/PROPOSAL. FAILURE TO COMPLY WITH THIS REQUIREMENT MAY RESULT IN THE BIDDER/PROPOSER BEING CONSIDERED NON-RESPONSIVE.**

**ALL OTHER TERMS AND CONDITIONS OF THE SOLICITATION DOCUMENTS ARE AND SHALL REMAIN THE SAME.**



Lilla Davis  
Procurement Analyst Direct Line: 239-533-8857  
Lee County Procurement Management