



Procurement Management Department
 2115 Second Street, 1st Floor
 Fort Myers, FL 33901
 Main Line: (239) 533-8881
 Fax Line: (239) 485-8383
www.leegov.com/procurement

Posted Date: April 5, 2023

Solicitation No.: B230207CMR

Solicitation Name: US41 North 16 Watermain Littleton Rd to Del Prado

Subject: Addendum Number 3

The following represents clarification, additions, deletions, and/or modifications to the above referenced bid. This addendum shall hereafter be regarded as part of the solicitation. Items not referenced herein remain unchanged, including the response date. Words, phrases or sentences with a strikethrough represent deletions to the original solicitation. Underlined words and bolded, phrases or sentences represent additions to the original solicitation.

1. QUESTIONS/ANSWERS

1.	Are you going to need to bypass the work area or are you shutting off the water in the main.
Answer	The Us 41 watermain is a transmission main serving North Lee County and is to remain in service. In accordance with Fire Department the LCU waterline shall remain in service until new watermain is fully operational. Any shutdowns or tie-ins are to be coordinated with LCU Operations, Department of Health, with the required notice.

BIDDER/PROPOSER IS ADVISED, YOU ARE REQUIRED TO ACKNOWLEDGE RECEIPT OF THIS ADDENDUM WHEN SUBMITTING A BID/PROPOSAL. FAILURE TO COMPLY WITH THIS REQUIREMENT MAY RESULT IN THE BIDDER/PROPOSER BEING CONSIDERED NON-RESPONSIVE.

ALL OTHER TERMS AND CONDITIONS OF THE SOLICITATION DOCUMENTS ARE AND SHALL REMAIN THE SAME.

Carolina Rodriguez

Carolina Rodriguez

 Procurement Analyst
 Direct Line: 239-533-8858
 Lee County Procurement Management