



Procurement Management Department  
 2115 Second Street, 1<sup>st</sup> Floor  
 Fort Myers, FL 33901  
 Main Line: (239) 533-8881  
 Fax Line: (239) 485-8383  
[www.leegov.com/procurement](http://www.leegov.com/procurement)

**Posted Date:** October 5, 2023

**Solicitation No.:** B230404CJV

**Solicitation Name:** Replacement of 500kw Trailer Mounted Generator

**Subject:** Addendum Number 3

The following represents clarification, additions, deletions, and/or modifications to the above referenced bid. This addendum shall hereafter be regarded as part of the solicitation. Items not referenced herein remain unchanged, including the response date. Words, phrases or sentences with a strikethrough represent deletions to the original solicitation. Underlined words and bolded, phrases or sentences represent additions to the original solicitation.

**1. QUESTIONS/ANSWERS**

1.	Is the bid bond mandatory for this bid?
<b>Answer</b>	<b>A bid bond is not applicable to this project.</b>
2.	I just noticed that the bid documents do not include any technical specifications regarding the ATS.
<b>Answer</b>	<b>This is a portable generator. There are no Automatic Transfer Switch specifications.</b>

**BIDDER/PROPOSER IS ADVISED, YOU ARE REQUIRED TO ACKNOWLEDGE RECEIPT OF THIS ADDENDUM WHEN SUBMITTING A BID/PROPOSAL. FAILURE TO COMPLY WITH THIS REQUIREMENT MAY RESULT IN THE BIDDER/PROPOSER BEING CONSIDERED NON-RESPONSIVE.**

**ALL OTHER TERMS AND CONDITIONS OF THE SOLICITATION DOCUMENTS ARE AND SHALL REMAIN THE SAME.**

[Christy VanAllen](#)

Christy VanAllen, Procurement Analyst  
 Lee County Procurement Management