



Procurement Management Department
2115 Second Street, 1st Floor
Fort Myers, FL 33901
Main Line: (239) 533-8881
Fax Line: (239) 485-8383
www.leegov.com/procurement

Posted Date: April 24, 2024

Solicitation No.: B240229LND

Solicitation Name: Veterans Pkwy Resurfacing - Bridge to Del Prado 3FY24A

Subject: Addendum Number 2

The following represents clarification, additions, deletions, and/or modifications to the above referenced bid. This addendum shall hereafter be regarded as part of the solicitation. Items not referenced herein remain unchanged, including the response date. Words, phrases or sentences with a strikethrough represent deletions to the original solicitation. Underlined words and bolded, phrases or sentences represent additions to the original solicitation.

1. ATTACHMENT:
None

2. QUESTIONS/ANSWERS

1.	The Bid item for asphalt is listed as “334-1-14B SuperPave Asphaltic Concrete FC 12.5 Traffic E”. Can you please clarify if the county is specifying SP-12.5 (Traffic Level E) or FC-12.5 (Traffic Level E). The 334 spec applies to SP12.5 (Traffic Level E); however, the item description is confusing.
Answer	Please bid as specified using FC-12.5 Traffic level E as the asphalt type to be used on this project.
2.	Additionally, is the mix required to include PG 76-22 binder?
Answer	No, the mix is not required to include PG 76-22 binder.

BIDDER/PROPOSER IS ADVISED, YOU ARE REQUIRED TO ACKNOWLEDGE RECEIPT OF THIS ADDENDUM WHEN SUBMITTING A BID/PROPOSAL. FAILURE TO COMPLY WITH THIS REQUIREMENT MAY RESULT IN THE BIDDER/PROPOSER BEING CONSIDERED NON-RESPONSIVE.

ALL OTHER TERMS AND CONDITIONS OF THE SOLICITATION DOCUMENTS ARE AND SHALL REMAIN THE SAME.

 Lilla Davis
 Procurement Analyst Direct Line: 239-533-8857
 Lee County Procurement Management