



Procurement Management Department
 2115 Second Street, 1st Floor
 Fort Myers, FL 33901
 Main Line: (239) 533-8881
 Fax Line: (239) 485-8383
www.leegov.com/procurement

Posted Date: 01/17/2025

Solicitation No.: B240472LND

Solicitation Name: Hurricane Ian Sidewalk Repairs on Hickory Blvd - LAP

Subject: Addendum Number 2

The following represents clarification, additions, deletions, and/or modifications to the above referenced bid. This addendum shall hereafter be regarded as part of the solicitation. Items not referenced herein remain unchanged, including the response date. Words, phrases or sentences with a strikethrough represent deletions to the original solicitation. Underlined words and bolded, phrases or sentences represent additions to the original solicitation.

1. REVISED SCOPE OF WORK AND SPECIFICATIONS

1.1. Lee County Board of County Commissioners seeks to contract with a qualified Contractor to repair and replace (R & R) portions of the sidewalk infrastructure along the east side of Hickory Blvd. due to substantial damage caused by Hurricane IAN on September 28, 2022. The affected area spans from 26131 to 27795 Hickory Blvd. Specifically, the project includes:

- Replacement of a concrete bus ramp at Beach Access #4, approximately 97 square yards (SY).
- R&R of ~~6447~~ **4,630** linear feet (LF) of asphalt sidewalk. **(Participating – Grant Funded)**
- **R&R of 4,800 linear feet (LF) of asphalt sidewalk (Non-Participating – County Funded)**
- R&R of 163 square yards of concrete sidewalk

2. ATTACHMENT

- **Updated Wage Rate Table issued January 3, 2025**

3. QUESTIONS/ANSWERS

1.	<p>Upon review of the solicitation documents, I am requesting clarification on a LF quantity difference as shown in the project documents. On the County’s General Scope of Work Summary document, it references the total linear footage of repairs to be 6447 LF. On the County’s Breakdown document, the total Sidewalk Repair Location Breakdown document references a total of 4587 LF.</p> <p>Please explain/clarify the County’s intend on the extent of Linear Footage to be Removed & Replaced for the project.</p>
Answer	<p>Please see revised Scope of Work listed above to reflect clarified totals including: R&R of 4,630 linear feet (LF) of asphalt sidewalk (Participating – Grant Funded) R&R of 4,800 linear feet (LF) of asphalt sidewalk (Non-Participating – County Funded)</p> <p>Bid schedule already reflects this correct amount in SY units.</p>

2.	Does the County have a price/budget estimate dollar amount for the project?
Answer	<p>Please refer to the Solicitation documents on page 8 under item 14 Confidentiality.</p> <p>14.3 Lee County <u>will not reveal engineering estimates or budget amounts for a project</u> unless required by grant funding or unless it is in the best interest of the County. Pursuant to § 337.168, F.S.: A document or electronic file revealing the official cost estimate of the department of a project is confidential and exempt from the provisions of § 119.07(1), F.S. until the Contract for the project has been executed or until the project is no longer under active consideration.</p>

3.	<p>Contractor is requesting clarification on bid line item 120-6 Embankment (Truckload) 750CY. The specification section does not clearly denote what material is to be used for embankment. See below, the 522-2 Materials spec calls out embankment, but then references spec section 520-2, which is not included in the project documents.</p> <p>522-2 Materials. Meet the requirements specified in 520-2 and the embankment utilization requirements of Standard Plans Index 120-001. What is the “embankment material” supposed to be comprised of?</p>
Answer	Embankment material shall have a Minimum of 40 LBR (Limerock Bearing Ratio).

4.	Where is the “embankment material” to be placed or used on the project? Is this material to be used as fill-in along the disturbed edges of the new sod after placement?
Answer	Placement areas will be field designated, some under the sidewalk and some on the sidewalk shoulders/slopes.

BIDDER/PROPOSER IS ADVISED, YOU ARE REQUIRED TO ACKNOWLEDGE RECEIPT OF THIS ADDENDUM WHEN SUBMITTING A BID/PROPOSAL. FAILURE TO COMPLY WITH THIS REQUIREMENT MAY RESULT IN THE BIDDER/PROPOSER BEING CONSIDERED NON-RESPONSIVE.

ALL OTHER TERMS AND CONDITIONS OF THE SOLICITATION DOCUMENTS ARE AND SHALL REMAIN THE SAME.



Lilla Davis
Procurement Analyst Direct Line: 239-533-8857
Lee County Procurement Management