



Procurement Management Department  
 2115 Second Street, 1<sup>st</sup> Floor  
 Fort Myers, FL 33901  
 Main Line: (239) 533-8881  
 Fax Line: (239) 485-8383  
[www.leegov.com/procurement](http://www.leegov.com/procurement)

**Posted Date:** December 11, 2024

**Solicitation No.:** B240506DJN

**Solicitation Name:** Melvin Morgan Generator Replacement

**Subject:** Addendum Number 1

The following represents clarification, additions, deletions, and/or modifications to the above referenced bid. This addendum shall hereafter be regarded as part of the solicitation. Items not referenced herein remain unchanged, including the response date. Words, phrases or sentences with a strikethrough represent deletions to the original solicitation. Underlined words and bolded, phrases or sentences represent additions to the original solicitation.

**OPEN DATE / BID DUE DATE EXTENSION NOTICE:**  
**FROM: ~~January 8, 2025; at 2:30 PM~~**  
**TO: January 21, 2025; at 2:30 PM**

**SITE VISIT SCHEDULED:**  
**DATE/TIME: December 17, 2024 at 10:30 A.M.**  
**Melvin Morgan Constitutional Complex**  
**2480 Thompson St, Fort Myers, FL 33901**

**1. QUESTIONS/ANSWERS**

1.	I would like to confirm, is this project exclusively designed for a Cummins generator or will Lee County be accepting equals meeting the specs?
Answer	<b>The Cummins generator is the Basis of Design. We will accept a generator manufactured by CAT or Detroit Diesel if the proposed product meets or exceeds all specifications for the specified Basis of Design.</b>
2.	Is it possible to setup a site visit, to provide a more accurate proposal?
Answer	<b>A site visit has been arranged for December 17, 2024 at 10:30 AM. This will be the only site visit scheduled for the project. We will meet in the parking lot near the proposed generator location. Parking is located across Thompson Steet in the public parking lot.</b>

**BIDDER/PROPOSER IS ADVISED, YOU ARE REQUIRED TO ACKNOWLEDGE RECEIPT OF THIS ADDENDUM WHEN SUBMITTING A BID/PROPOSAL. FAILURE TO COMPLY WITH THIS REQUIREMENT MAY RESULT IN THE BIDDER/PROPOSER BEING CONSIDERED NON-RESPONSIVE.**

**ALL OTHER TERMS AND CONDITIONS OF THE SOLICITATION DOCUMENTS ARE AND SHALL REMAIN THE SAME.**

Darvis Napier  
 Darvis Napier  
 Procurement Analyst Direct Line: 239-533-8863  
 Lee County Procurement Management