



Procurement Management Department
 2115 Second Street, 1st Floor
 Fort Myers, FL 33901
 Main Line: (239) 533-8881
 Fax Line: (239) 485-8383
www.leegov.com/procurement

Posted Date: January 14, 2025

Solicitation No.: B240506DJN

Solicitation Name: Melvin Morgan Generator Replacement

Subject: Addendum Number 3

The following represents clarification, additions, deletions, and/or modifications to the above referenced bid. This addendum shall hereafter be regarded as part of the solicitation. Items not referenced herein remain unchanged, including the response date. Words, phrases or sentences with a strikethrough represent deletions to the original solicitation. Underlined words and bolded, phrases or sentences represent additions to the original solicitation.

OPEN DATE / BID DUE DATE EXTENSION NOTICE:
FROM: ~~January 21, 2025; at 2:30 PM~~
TO: January 28, 2025; at 2:30 PM

1. UPDATED BID SCHEDULE

The Bid Schedule has been updated and a revised Bid Schedule has been uploaded to the solicitation webpage on the Lee County Procurement website.

Please ensure that your firm has downloaded the revised Bid Schedule and have been able to successfully use the Excel format. Any firm having compatibility issues or difficulty downloading the revised Bid Schedule needs to contact the Procurement Analyst for this project at their earliest convenience. Do not wait until submission day to download. Procurement is not required to extend a closing due to Contractor delay or difficulty in receipt of download of documents.

Bidders MUST use the **Addendum 3 Revised** Bid Schedule Excel Form when submitting their bid. Failure to do so will result in Bidder being deemed non-responsive and therefore ineligible for award.

2. ARTICLE ADDITIONS

a. **ADDITIONS GENERAL SCOPE OF WORK 1.1.6 SITE DEMOLITION CONTRACTOR shall salvage the existing generator and provide the County with a credit to be used towards the project total.**

3. QUESTIONS/ANSWERS

1.	<p>Can you please confirm:</p> <p>A: Plan Drawing E201 mentions Hurricane-Rated enclosure; does this mean High-Velocity Hurricane Zone (HVHZ) Impact Rated?</p> <p>B: Will wind resistant up to 180 mph be sufficient?</p> <p>Below sections does not mention HVHZ Impact</p>
----	---

	*Generator specs 2.9.A mentions wind resistant up to 180 mph *Riser Drawing E201 mentions Level 2 sound-attenuated enclosure
Answer	Provide weather-resistant generator enclosure rated for both HVHZ impact and Sound Attenuation Level 2 noise control.
2.	How long do we have to complete this work after awarded?
Answer	From the Notice to Proceed or the Purchase Order date, whichever applies: 600 calendar days to substantial completion, 30 calendar days from substantial completion to final completion (total days 630).

BIDDER/PROPOSER IS ADVISED, YOU ARE REQUIRED TO ACKNOWLEDGE RECEIPT OF THIS ADDENDUM WHEN SUBMITTING A BID/PROPOSAL. FAILURE TO COMPLY WITH THIS REQUIREMENT MAY RESULT IN THE BIDDER/PROPOSER BEING CONSIDERED NON-RESPONSIVE.

ALL OTHER TERMS AND CONDITIONS OF THE SOLICITATION DOCUMENTS ARE AND SHALL REMAIN THE SAME.

Davis Napier

Davis Napier
Procurement Analyst Direct Line: 239-533-8863
Lee County Procurement Management