



Posted Date: May 9, 2025

Solicitation No.: B250106LND

Solicitation Name: Orange River Blvd. Sidewalk and Watermain Replacement

Subject: Addendum Number 5

The following represents clarification, additions, deletions, and/or modifications to the above referenced bid. This addendum shall hereafter be regarded as part of the solicitation. Items not referenced herein remain unchanged, including the response date. Words, phrases or sentences with a strikethrough represent deletions to the original solicitation. Underlined words and bolded, phrases or sentences represent additions to the original solicitation.

1. QUESTIONS/ANSWERS

1.	Please reference Sheet 69 - Utility Plan and Profiles (Orange River Blvd STA 10+00.00 to STA 23+40): Plan View Calls for Existing 6” AC WM to be Removed and existing 12” PVC WM too Remain. Profile View Calls for Existing 6” PVC WM to be Removed and Existing 12” PVC WM to Remain. Is the existing 6” WM AC or PVC? Significant difference in handling and disposal costs.
Answer	After review, the existing WM is AC, not the PVC mentioned in the Profile View. Please bid using the Plan View that calls for 6” AC WM to be removed.

2.	How often is sod maintained in the project area?
Answer	Sod maintenance is a contractor means and methods item.

3.	How many times per month will trash be needing to be picked up and when does that start?
Answer	Up to 8 litter removal times are included under item 107-1-1 Litter Removal on the Bid Schedule and is from the start of construction. Litter removal should be done before mowing.

4.	What days is trash collected in the project area
Answer	Trash is to be collected on Friday. Contactor shall contact Solid Waste at the start of the project to verify date/time of pick up.

5.	How many times will it need mowing to be done and when does that start?
Answer	Up to 8 mowing times are included under item 107-2-4 Mowing (Small Machines) on the bid schedule and is from the start of construction.

BIDDER/PROPOSER IS ADVISED, YOU ARE REQUIRED TO ACKNOWLEDGE RECEIPT OF THIS ADDENDUM WHEN SUBMITTING A BID/PROPOSAL. FAILURE TO COMPLY WITH THIS REQUIREMENT MAY RESULT IN THE BIDDER/PROPOSER BEING CONSIDERED NON-RESPONSIVE.

ALL OTHER TERMS AND CONDITIONS OF THE SOLICITATION DOCUMENTS ARE AND SHALL REMAIN THE SAME.



Lilla Davis
Procurement Analyst Direct Line: 239-533-8857
Lee County Procurement Management