

Posted Date: April 11, 2024

Solicitation No.: Q240258WCD

Solicitation Name: Matlacha Park Split-Rail Fencing Repairs/Replacement-Hurricane Ian

Subject: Addendum Number 1

The following represents clarification, additions, deletions, and/or modifications to the above referenced bid. This addendum shall hereafter be regarded as part of the solicitation. Items not referenced herein remain unchanged, including the response date. Words, phrases or sentences with a strikethrough represent deletions to the original solicitation. Underlined words and bolded, phrases or sentences represent additions to the original solicitation.

1. ATTACHMENTS

2. QUESTIONS/ANSWERS

| 1. | Particularly, we would like to know whether the concrete is a 18"X12"X12" pre-formed concrete? |
|--------|--|
| Answer | No, the concrete is not intended to be provided as 18"x12"x12" pre-formed pieces. Rather, it is intended to be poured into the 7 holes, surround the post bases, and solidify as 18"x12"x12" blocks. |
| | |
| 2. | In addition, we want to know if ready-mix concrete is specified for the post installation? |
| Answer | No; packaged concrete can be used around the 7 post bases. |

BIDDER/PROPOSER IS ADVISED, YOU ARE REQUIRED TO ACKNOWLEDGE RECEIPT OF THIS ADDENDUM WHEN SUBMITTING A BID/PROPOSAL. FAILURE TO COMPLY WITH THIS REQUIREMENT MAY RESULT IN THE BIDDER/PROPOSER BEING CONSIDERED NON-RESPONSIVE.

ALL OTHER TERMS AND CONDITIONS OF THE SOLICITATION DOCUMENTS ARE AND SHALL REMAIN THE SAME.

Willie Dennard

Analyst Name-Willie Dennard Procurement Analyst Direct Line: 239-533-8831 Lee County Procurement Management