



Procurement Management Department
 2115 Second Street, 1st Floor
 Fort Myers, FL 33901
 Main Line: (239) 533-8881
 Fax Line: (239) 485-8383
www.leegov.com/procurement

Posted Date: March 29, 2024

Solicitation No.: B240122DWJ

Solicitation Name: North Lee County Wellfield Expansion Phase III-B

Subject: Addendum Number 1

The following represents clarification, additions, deletions, and/or modifications to the above referenced bid. This addendum shall hereafter be regarded as part of the solicitation. Items not referenced herein remain unchanged, including the response date. Words, phrases or sentences with a strikethrough represent deletions to the original solicitation. Underlined words and bolded, phrases or sentences represent additions to the original solicitation.

1. PRE-PROPOSAL MEETING NOTICE:

Type: Non-Mandatory
 Date/Time: 4/11/2024 at 9:00 AM
 Location: Telegraph Creek Preserve, Argo Dr., Alva, FL 33920

2. ATTACHMENTS

3. QUESTIONS/ANSWERS

1.	Is it possible to schedule a site visit for the below listed project? We need to be able to estimate the clearing and fill needed to prep each well site.
Answer	A non-mandatory pre-bid has been scheduled for April 11, 2024, at 9:00 am at the Telegraph Creek Preserve located at Argo Dr., Alva, FL 33920.

2.	Can you provide the name of the Surveyor used by Stantec?
Answer	Please see the information block on plan sheet G-002 of Attachment 1 – North LC WTP Wellfield Expansion Phase III-B Plan Set. Consultant is RMA Geologic Consultants, Inc.

3.	We would likely drill a shallow 4" well at each site for construction water. At completion of the project, we would abandon those wells. Would this water be acceptable for use in the Acidization and Disinfection?
Answer	Yes. Note that as included in the Technical Specifications, the Contractor is responsible for repeating the disinfection procedure if any of the two samples are positive for total coliform.

4.	Is the Hydrochloric Acid required to be Food Grade NSF?
Answer	Yes


5.	Why is there no pre-bid conference planned for this project?
Answer	A non-mandatory pre-bid has been scheduled for April 11, 2024, at 9:00 am at the Telegraph Creek Preserve located at Argo Dr., Alva, FL 33920.

6.	Will we be able to have a pre-bid conference and visit the site?
----	--

Answer	A non-mandatory pre-bid has been scheduled for April 11, 2024, at 9:00 am at the Telegraph Creek Preserve located at Argo Dr., Alva, FL 33920.
7.	What is the start date for construction?
Answer	Currently, a start date for construction has not been set. The County anticipates starting construction late Fall or Winter 2024.
8.	What is the estimated value for this project?
Answer	See 13.3 of the project solicitation. Lee County will not reveal engineering estimate or budget amounts for a project unless required by grant funding or unless it is in the best interest of the County.
9.	Are there union requirements for this project?
Answer	There are no union requirements for this project.
10.	Good morning, can we do a site visit to see the sites for clearing and for water discharge?
Answer	A non-mandatory pre-bid has been scheduled for April 11, 2024, at 9:00 am at the Telegraph Creek Preserve located at Argo Dr., Alva, FL 33920.

BIDDER/PROPOSER IS ADVISED, YOU ARE REQUIRED TO ACKNOWLEDGE RECEIPT OF THIS ADDENDUM WHEN SUBMITTING A BID/PROPOSAL. FAILURE TO COMPLY WITH THIS REQUIREMENT MAY RESULT IN THE BIDDER/PROPOSER BEING CONSIDERED NON-RESPONSIVE.

ALL OTHER TERMS AND CONDITIONS OF THE SOLICITATION DOCUMENTS ARE AND SHALL REMAIN THE SAME.


 David Jones
 Procurement Analyst Direct Line: 239-533-8864
 Lee County Procurement Management