



Procurement Management Department
 2115 Second Street, 1st Floor.
 Fort Myers, FL 33901
 Main Line: (239) 533-8881
 Fax Line: (239) 485-8383
www.leegov.com/procurement

Posted Date: March 25, 2024

Solicitation No.: B240151DWJ

Solicitation Name: Three Oaks WRF DIW-2

Subject: Addendum Number 2

The following represents clarification, additions, deletions, and/or modifications to the above referenced bid. This addendum shall hereafter be regarded as part of the solicitation. Items not referenced herein remain unchanged, including the response date. Words, phrases or sentences with a strikethrough represent deletions to the original solicitation. Underlined words and bolded, phrases or sentences represent additions to the original solicitation.

1. ATTACHMENTS

2. QUESTIONS/ANSWERS

1.	The plans call for 6” flange Air Release Valves and the specs call for 4” flange Air Release Valves. Which size is required?
Answer	There are a couple of ARV’s per plans Page M-103 one is a 6” with a coupled 2” and then further down line is 4” coupled with a 2”.
2.	The plans call for 316 SS gate valves, however the specs do not call out 316 SS gate valves. Is 316 SS required for all gate valves?
Answer	Only gate valves that are within the surface facilities.

BIDDER/PROPOSER IS ADVISED, YOU ARE REQUIRED TO ACKNOWLEDGE RECEIPT OF THIS ADDENDUM WHEN SUBMITTING A BID/PROPOSAL. FAILURE TO COMPLY WITH THIS REQUIREMENT MAY RESULT IN THE BIDDER/PROPOSER BEING CONSIDERED NON-RESPONSIVE.

ALL OTHER TERMS AND CONDITIONS OF THE SOLICITATION DOCUMENTS ARE AND SHALL REMAIN THE SAME.

David Jones
 David Jones
 Procurement Analyst Direct Line: 239-533-8864
 Lee County Procurement Management