



Posted Date: March 15, 2023

Solicitation No.: B230154DWJ

Solicitation Name: Wastewater Collection System Rehabilitation

Subject: Addendum Number 1

The following represents clarification, additions, deletions, and/or modifications to the above referenced bid. This addendum shall hereafter be regarded as part of the solicitation. Items not referenced herein remain unchanged, including the response date. Words, phrases or sentences with a strikethrough represent deletions to the original solicitation. Underlined words and bolded, phrases or sentences represent additions to the original solicitation.

1. ATTACHMENT: (1)
 - ATTACHMENT B – Technical Specifications


2. QUESTIONS/ANSWERS

1.	SECTION 02770 CIP FULL CIRCLE MAIN / LATERAL CONNECTION – 1.2 General A: Last Sentence “ <i>The cured-in-place mainline/lateral connection repair system shall be “T-Liner” or approved equal.</i> ” Question – T-Liner is “proprietary” product that only one installer in south FL can install, that makes Section D, sole source. Is this what the County intended? Question – How do you become an “approved equal”?
Answer	This specification has been proven in this area of Florida to continue to reduce and eliminate ground water due to the sealing of this product. This installation and use of this product is not a sole source, licenses can be obtained to complete the installation and purchase of this product. There is an option to utilize this product through sub-contracting as well.
2.	2.3 LINER MATERIAL - B. <i>The liner shall meet or exceed ASTM F2561-06.</i> Question – The ASTM F 2561-06 is a proprietary “specification”, again that makes this a “sole source bid”. Is that what the County intended?
Answer	This specification has been proven in this area of Florida to continue to reduce and eliminate ground water due to the sealing of this product. This installation and use of this product is not a sole source, licenses can be obtained to complete the installation and purchase of this product. There is an option to utilize this product through sub-contracting as well.
3.	BLD Services, LLC has been lining laterals in Florida for over 10 years and is the largest lateral lining company in the state and the USA. We request the opportunity to be listed as an “approved product”.
Answer	Lee County has a process set in place to review and approve new products. Please visit the Lee County Utilities website to submit products for future review under Design Manual, Approved Materials. See link: https://www.leegov.com/utilities/design-manual/approved-materials

4.	Could you please share specifications related to manhole rehabilitation for the subject project?
Answer	Please see ATTACHMENT B – Technical Specifications

BIDDER/PROPOSER IS ADVISED, YOU ARE REQUIRED TO ACKNOWLEDGE RECEIPT OF THIS ADDENDUM WHEN SUBMITTING A BID/PROPOSAL. FAILURE TO COMPLY WITH THIS REQUIREMENT MAY RESULT IN THE BIDDER/PROPOSER BEING CONSIDERED NON-RESPONSIVE.

ALL OTHER TERMS AND CONDITIONS OF THE SOLICITATION DOCUMENTS ARE AND SHALL REMAIN THE SAME.



Procurement Analyst – David Jones
Procurement Analyst Direct Line: 239-533-8864
Lee County Procurement Management