



Procurement Management Department  
2115 Second Street, 1<sup>st</sup> Floor  
Fort Myers, FL 33901  
Main Line: (239) 533-8881  
Fax Line: (239) 485-8383  
[www.leegov.com/procurement](http://www.leegov.com/procurement)

**Posted Date:** April 3, 2023

**Solicitation No.:** B230154DWJ

**Solicitation Name:** Wastewater Collection System Rehabilitation

**Subject:** Addendum Number 2

The following represents clarification, additions, deletions, and/or modifications to the above referenced bid. This addendum shall hereafter be regarded as part of the solicitation. Items not referenced herein remain unchanged, including the response date. Words, phrases or sentences with a strikethrough represent deletions to the original solicitation. Underlined words and bolded, phrases or sentences represent additions to the original solicitation.

**1. ATTACHMENT: (1)**

- **RFP170241DLK Contract – Exhibit B – Attachment 1 Fee Schedule**


**2. QUESTIONS/ANSWERS**

1.	Groups E and F reference two different types of pipe lining. To my knowledge, there is only one contractor in the state of Florida with the capability to perform both methods for pipe lining. The basis of award says, “Vendor must bid all line items in Groups A-F to be eligible for award”. This limits the bid to one contractor as a sole source. Can this be revised to allow contractors to bid each group individually (bidding all items for the specific group) based on their field of expertise and experience?
Answer	<b>The installation and use of these pipe liner products are not a sole source, licenses can be obtained to complete the installation and purchase of these products. There is an option to utilize these services and products through sub-contracting as well. There will be no revision to the bid requirements at this time.</b>
2.	Are the full bid tabulations for the previous project for this work available and can they be provided. Solicitation No: RFP170241DLK Project Title: Wastewater Collection System.
Answer	<b>Only two submissions were received per solicitation No. RFP170241DLK. Please see link for the bid tabulation <a href="https://www.leegov.com/procurement/awarded-annual-contracts/downloads?fid=4992&amp;fn=Project2017-07-14T06_56_13.xml">https://www.leegov.com/procurement/awarded-annual-contracts/downloads?fid=4992&amp;fn=Project2017-07-14T06_56_13.xml</a></b> <b>The full bid tabulation is Exhibit B – Attachment 1 Fee Schedule of the current contract that is available on the Lee County Procurement Management Awarded Annual Contracts page under the project name Wastewater Collection System – RFP170241DLK and has been attached to this addendum.</b>
3.	We are aware the deadline for questions has passed, but wanted to inform you that the bid pay item description for the below pay item does not match what is listed on the bid schedule form. The pay item description says each and the bid form says LF. Can you please confirm which one it is?  Items D22 to D23 – Install Full-Circle CIP mainline/lateral connection

	interface seal 6-in to 21-inch main, 4-inch & 6-inch lateral pipe, up to 6-inch of lateral piping, all depths. (1) This item will be paid at the unit price per each
<b>Answer</b>	<b>This will be for linear feet.</b>

**BIDDER/PROPOSER IS ADVISED, YOU ARE REQUIRED TO ACKNOWLEDGE RECEIPT OF THIS ADDENDUM WHEN SUBMITTING A BID/PROPOSAL. FAILURE TO COMPLY WITH THIS REQUIREMENT MAY RESULT IN THE BIDDER/PROPOSER BEING CONSIDERED NON-RESPONSIVE.**

**ALL OTHER TERMS AND CONDITIONS OF THE SOLICITATION DOCUMENTS ARE AND SHALL REMAIN THE SAME.**

  
 Procurement Analyst – David Jones  
 Procurement Analyst Direct Line: 239-533-8864  
 Lee County Procurement Management