



- ① FINISHED GRADE
- ② PEDESTAL HOUSING (SEE APPPROVED MATERIAL LIST)  
COLORS: BLUE - WATER, GREEN - SEWER, PANTONE PURPLE - REUSE
- ③ EDGE OF RIGHT-OF-WAY
- ④ PVC STREET ELL
- ⑤ S.S. POST WITH S.S. HARDWARE & S.S. LOCKING HASP WITH BRASS LOCK

- ⑥ SHORT BODY AUTOMATIC AIR RELEASE VALVE (SEE APPPROVED MATERIAL LIST) ALL INTERNAL WORKING PARTS SHALL BE 300 SERIES STAINLESS STEEL.
- ⑦ PVC SCHEDULE 80
- ⑧ PVC REDUCER IF NEEDED
- ⑨ BRASS BALL CORP. STOP
- ⑩ 2" POLY-TUBE
- ⑪  $\frac{3}{4}$ " GRANULAR MATERIAL, #57 STONE
- ⑫ 2" BRASS FITTING IF NECESSARY
- ⑬ 1% MIN. SLOPE UP, 2" POLY-TUBE
- ⑭ TAP AT CROWN OF PIPE
- ⑮ 2" DOUBLE STRAP TAPPING SADDLE (SEE APPPROVED MATERIAL LIST)
- ⑯ EXISTING PRESSURE MAIN
- ⑰ 24"
- ⑱ 30" MIN.
- ⑲ 30"X30"X6" MIN. CONCRETE PAD



LEE COUNTY  
UTILITIES  
ENGINEERING  
1500 MONROE STREET  
FORT MYERS, FLORIDA 33901

TITLE:

ARV DETAIL

REVISION:

12/18/24

DETAIL NO:

G-04.dwg

**NOT TO SCALE**